LMS Technologies, Inc.
6423 Cecilia Circle, Bloomington, MN 55439
(952) 918-9060, Fax (952) 918-9061

Date: 04/12/2010
Type: ULPA TEST
Flow Rate: 35cfm
ID# : OF712UL

Requested by:
Atrix International, Inc.
Manufactured By:
Atrix International, Inc.

FILTER ID #	EFFICIENCY	PASS	FAIL	ΔP "H2O
OF712UL	99.999 @ 0.12 micron	x		3.237